



ESTUARY WATER QUALITY UPDATE

Water samples were taken from within the Knysna estuary and various Knysna culverts 19 - 22 January 2018. According to the national Department of Water Affairs guidelines, target water quality for recreational use may not exceed 500 E.coli/100ml.

The recent water samples were analysed by an independent laboratory to determine E.Coli levels within the water.

Estuary Recreation Point

1. Belvidere:	30/100ml
2. Bollard Bay:	No Growth/100ml
3. Crabs Creek:	No Growth/100ml
4. Green Hole:	10/100ml
5. KADA Culvert:	No Growth/100ml
6. Salt River:	No Growth/100ml
7. The Heads:	7/100ml
8. The Point:	1/100ml

Culvert

1. Ashmead:	2500/100ml
2. Bigai:	30/100ml
3. Bongani:	16000/100ml
4. Long Street:	3000/100ml
5. Queen Street:	No Growth/100ml
6. Train Station:	16000/100ml