



ESTUARY WATER QUALITY UPDATE

Water samples were taken from within the Knysna estuary and various Knysna culverts on 6 August 2024. According to the national Department of Water Affairs guidelines, target water quality for recreational use may not exceed 500 E.coli/100ml.

The recent water samples were analysed by an independent laboratory to determine E.Coli levels within the water.

Estuary Recreation Point

1. Belvidere:	300/100ml	
2. Bollard Bay:	3/100ml	
3. Costa Sarda (new)	>15000/100ml	NC
4. Crabs Creek:	13/100ml	
5. Green Hole:	50/100ml	
6. Lake Brenton (new)	50/100ml	
7. Salt River:	>15000/100ml	NC
8. The Heads:	17/100ml	

Culvert

1. Bigai:	40/100ml	
2. Bongani:	1500/100ml	NC
3. KADA:	No Growth	
4. Long Street:	>15000/100ml	NC
5. Queen Street:	900/100ml	NC
6. Train Station:	>15000/100ml	NC