



Knysna

Municipality || Munisipaliteit || uMasipala

inclusive || innovative || inspired

Electrical Department

25 July 2025

Att: Mr. C. Bouwer

Confirmation letter for available capacity indicated on the following property – Erf 5008, Island, Sedgefield.

This letter confirms the availability of electrical supply for your proposed property development at Erf 5008.

We've conducted several site inspections and tests on the existing minisub that feeds the properties adjacent to Erf 5008. As of our findings we can confirm that there's more than sufficient available capacity to supply your property.

Your consulting engineers, De Villiers & Moore, have estimated your required Notified Demand at 115kVA (175A). Our calculations indicate that it should be 120kVA (175A), however we can confirm at least 206kVA (300A) of spare capacity is available on the minisub for a dedicated supply to your property currently.

A quotation for the augmentation will be done once you have completed an application form. Please ensure the final indication of your required Notified Demand is clearly stated on this form for accurate quotation purposes. Once quotation has been done and the payment has been made, this will secure the required supply to your property.

The entire electrical connection must be carried out by a municipal electrical contractor who is familiar with our requirements and standards. This installation will involve the installation of a feeder breaker in the minisub adjacent to your property, which will feed into a new Golnix metering kiosk, to be installed as part of this installation. To be installed next to the minisub, and it must be accessible to Knysna Municipality at all times and will house a tariff breaker that feeds Erf 5008. The installation will include all cabling, etc. Sizes will be indicated on the quotation for augmentation. The account for the total installation will be directly between the customer and the municipal electrical contractor.

Power Measurement, our current provider for bulk meter installations and programming, will supply, install, program, and commission this meter. Please be aware that the account for the total supply and installation of the bulk meter itself will be directly between the customer and Power Measurement.

Our responsibility ends at the metering kiosk. From there, you will need to run a supply cable to your property's distribution kiosk and manage the internal reticulation to the different sections and separate electrical installations on the property.

Please note: We require copies of Certificates of Compliance (CoCs) for all separate electrical installations on your property. Adhering to this agreement, in terms of electrical regulations SANS 10142, is crucial to prevent disconnection of the electrical supply. Only the augmentation fee will be payable directly to Knysna Municipality.

Should you require a separate builders' supply point for construction purposes, a separate application can be made, and a quotation will be worked out based on those specific requirements.

If you have any further questions or need assistance with the application form, please do not hesitate to contact us.

Sincerely

Jaco Barnard

Senior Superintendent Electrical (Sedgefield Section)

Knysna Municipality