KNYSNA
Municipality
Munisipaliteit
uMasipala

LAND USE APPLICATION DEPARTMENT COMMENTS

Erf Number: 103953000
Application Type: Departure;Removal of Restrictions
Application Number: 3047
Application Date: 2024-04-12

Department	Comment Requested (T=Yes / F=No)	Comment Received
Corporate Services	F	
Legal Services	F	
Financial Services	F	
Community Services	F	
Fire Services	F	
Traffic	F	
Waste Removal	F	
Infrastructure Services	T	--oOo-- Thu Jun 06 2024 15:44:52 GMT+0200 (South Africa Standard Time) Comment by SASSM: * The as-built plans must include and show all boundaries and building lines. All access points must be indicated and all dimensions must be indicated. The provided information is sot sufficient to comment on. * Sewer layout plan attached. --oOo-- Fri Oct 18 2024 08:39:04 GMT+0200 (South Africa Standard Time) Additional Comment by SASSM: The attached plan is not a true reflection of the site. An as-built plan must be submitted and endorsed by the Builing Control Officer to confirm accuracy prior to the department review.
Infrastructure Services Roads	T	--oOo-- Tue Dec 17 2024 08:48:59 GMT+0200 (South Africa Standard Time) Additional Comment by SASSM: The attached plan is not a accurate reflection of the site. Town Planning must do an inspection and verify before asking for comments.
Infrastructure Services Sewer	T	--oOo-- Fri Oct 18 2024 08:41:00 GMT+0200 (South Africa Standard Time) Additional Comment by SASSM: The attached plan is not a true reflection of the site . An as-built plan must be submitted and endorsed by the Building Control Officer to confirm accuracy prior to the department review.
Electro Technical	F	
Housing	F	
Environmental Services	F	
Building Control	F	
Aesthetics Committee	F	
Street Naming Committee	F	